

Product Specification

PTI Arizona Test Dust A4 coarse

TÜV NORD Systems GmbH &
Co. KG
Plant & Product Safety
Refrigeration & Air Quality

Am TÜV 1
45307 Essen, Germany



1. General description: The coarsest test dust of ISO 12103-1 is the Arizona test dust A4 coarse.

The so-called Arizona test dust A4 coarse consists of 69 % - 77 % quartz.

2. Composition: The specified particle size distribution is shown in the following table:

x (µm)	Q3(x) (%)
0.97	0.74 - 0.83
1.38	1.8 - 2.1
2.75	5.5 - 6.3
5.50	11.5 - 12.5
11.0	21.0 - 23.0
22.0	36.0 - 38.5
44.0	58.0 - 60.0
88.0	85.0 - 86.5
124.50	93.0 - 94.0
176.0	97.2 - 98.2
248.90	99.0 - 100.0
352.0	100



3. Transport and Storage:	Partial segregation may occur during transport and storage. It is therefore recommended to homogenize the PTI Arizona Test Dust A4 coarse before use, which can be achieved by mixing with a laboratory tumbler mixer. Please store in a dry and airtight original container.
<hr/>	
4. Quality ensurance:	<p>In order to achieve reproducible quality, the raw materials and production are strictly controlled. The following quality controls are carried out:</p> <p>Monitoring the particle size distribution of raw materials Monitoring the particle size distribution of the end product</p>
<hr/>	
5. Specification:	<p>Name : PTI Arizona Test Dust A4 coarse Synonyme : AC coarse, coarse test dust Standard: ISO 12103-1 Title of Standard: Road vehicles -- Test contaminants for filter evaluation -- Part 1: Arizona test dust Composition : Quarz Material: Quartz largest particle size (µm) : 352 Bulk density (g/cm³): 1,20 Substance density (g/cm³) : 2,65 Apperance : solid Hardness (Mohs): 7,0 Colour : brown / beige</p>
