

Product Specification

DMT Test Dust A2 fine quartz-free

DMT GmbH & Co. KG
 Plant & Product Safety
 Refrigeration & Air Quality

Am TÜV 1
 45307 Essen, Germany



1. General description: The best-known normative test dust for filter tests and environmental simulations is the Arizona test dust A2 fine, which is described in ISO 12103-1 with regard to its composition and particle size distribution. It is used for tests according to ISO 5011, IEC 62885 (DIN EN 60312), 32-SAMSS-008 (ARAMCO) or the new ISO 16890-3. Since the test dust consists mainly of quartz and has an average value $d_{50.3} < 10 \mu\text{m}$, there is an increased health risk potential due to the alveolar fraction. (Carcinogen, TRGS 906)

For this reason DMT GmbH & Co. KG has developed an alternative test dust, the so-called DMT test dust A2 fine quartz-free, which consists mainly of calcium magnesium carbonate and is not evaluated as a carcinogenic hazardous substance.

2. Composition: The particle size distribution of DMT Test Dust A2 fine quartz-free is between 0 - 120 μm .

3. Transport and Storage: Partial segregation may occur during transport and storage. It is therefore recommended to homogenize the DMT Test Dust A2 fine quartz-free before use, which can be achieved by mixing with a laboratory tumbler mixer. Please store in a dry and airtight original container.

4. Quality ensurance: In order to achieve reproducible quality, the raw materials and production are strictly controlled. The following quality controls are carried out:

- Monitoring the particle size distribution of raw materials
- Monitoring the particle size distribution of the end product



5. Specification:

Name : DMT Test Dust A2 fine quartz-free

Composition : Calcium magnesium carbonate

Material: Dolomite

largest particle size (μm) : 120

Substance density (g/cm^3) : 2,85

Apperance : solid

Hardness (Mohs): 3,5

Colour : white